



**SPECIFICATIONS**

MATERIAL AND CONSTRUCTION SHALL COMPLY WITH PENN DOT PUB 408  
 CLASS AA CONCRETE MINIMUM STRENGTH 4000 P.S.I @ 28 DAYS  
 REINFORCEMENT~ A.S.T.M. A615 GRADE 60, MIN 1 1/2" COVER.  
 1 1/2" DIA TAPERED LIFT PINS RECOMMENDED FOR LIFTING



**PENN D.O.T. 4FT. MODIFIED TYPE C INLET TOP**

DATE: 2-00	SIGNATURE OF APPROVAL	DWG NO. CTLST0017	NAME: BTH
---------------	-----------------------	----------------------	--------------